

An Energy Efficiency Workshop & Exposition
Palm Springs, California

## Please be courteous to our speakers





Turn off all cell phones and Set pagers to vibrate



An Energy Efficiency Workshop & Exposition

Palm Springs, California

Counting the Benefits of ESPCs: Energy Savings and More

Phil Wirdzek

National Energy Manager U.S. EPA



## EPA Energy Use

- The U.S. EPA collects energy and water consumption data from its 20 owned laboratories
- **E.O.** 13123: 20% reduction by 2005
  - Spirit of Executive Order to reduce emissions
  - Specifies <u>laboratories</u> as part of Federal energy reduction efforts
  - > How do we get there?

June 2 -5, 2002

www.energy2002.ee.doe.gov

- 2



## NVFEL – Ann Arbor, MI



June 2 -5, 2002

www.energy2002.ee.doe.gov



## National Vehicle and Fuel Emissions Laboratory (NVFEL)

#### **Background**

- □ 135,000 square foot facility in Ann Arbor, Michigan
- Requires precise environmental control under widely varying load conditions
- One of EPA's most energy intensive sites
  - Using almost 3 MW per year
  - Over \$1 million in annual utility costs

June 2 - 5, 2002

www.energy2002.ee.doe.gov

-



## NVFEL - Ann Arbor, MI

#### The Need:

- 30 year old energy infrastructure in dire need of replacement. For example:
  - Test cell AHUs before ESPC conditioned 100% outside air to supply space, and air was then exhausted after the first pass
  - Baseline water consumption 31,373,000 gallons/year

June 2 -5, 2002

www.energy2002.ee.doe.gov



### NVFEL – Ann Arbor, MI

#### The Answer? ESPC

- Reduce source emissions, energy consumption, and energy costs through 11 ECMs
- Exceed federal energy reduction mandates
- Eliminate CFCs
- Reduce water consumption
- Minimize wasted energy
- Provide simple payback on contractor's capital expenditure of less than 10 years
- NORESCO

June 2 -5, 2002

www.energy2002.ee.doe.gov

7



#### NVFEL – ECM 1

#### Test Cell AHUs

- Replace 14 rooftop AHUs supplying the test cells
  - Removal of old units, steam piping, humidifiers, and exhaust fans
- New units installed with:
  - Indirect evaporative coolers, preheat coils, cooling coils with face and bypass dampers and spray atomizing humidifiers
  - > New temperature controllers

June 2 - 5, 2002

www.energy2002.ee.doe.gov



## **NVFEL - ECM 1 & 2**





June 2 -5, 2002

www.energy2002.ee.doe.gov

9



## NVFEL - ECM 2

#### Soak Area AHUs

- □ Four roof-mounted HVAC units installed to serve soak areas
  - > Water heated and cooled
  - > Total energy recovery wheel installed to precondition air supply
- New temperature controls
  - Maintain space conditions
  - Remote monitoring of units, remote set point adjustment

June 2 -5,2002

 $www.\,energy 2002.ee.doe.gov$ 



#### Office Preparation AHUs

- Removed 11 roof-mounted HVAC systems for offices, controls rooms, labs, and preparation rooms
- New units installed
  - > Return air, preheat coils, cooling coils
  - > New temperature controllers

June 2 - 5, 2002

www.energy2002.ee.doe.gov

11



#### NVFEL - ECM 4

## Replace Boilers and Chillers

- Provided NVFEL with entirely new heating and cooling plant
- Water chillers converted from CFC-based mechanical refrigeration to non-CFC, twostage absorption technology
- High-pressure steam boilers removed, now generated by same absorption units

June 2 - 5, 2002

www.energy2002.ee.doe.gov



## **NVFEL** – **ECM 4** (cont'd)

- New cooling tower installed on roof
  - Removed existing one from site
- □ Existing 5,000 gallon fuel oil tank remains intact outside boiler room
  - Serves as back-up for dual fuel absorbers and for the emergency genset

June 2 -5, 2002

www.energy2002.ee.doe.gov

13



## **NVFEL** – **ECM** 4 (cont'd)





June 2 - 5, 2002

www.energy2002.ee.doe.gov



## Install Energy Management System (EMS)

- □ In the past, control of HVAC equipment was performed manually
  - > HVAC systems ran excessively due to various occupancy schedules
- NORESCO proposed and installed state-of-theart EMS that controls building temperature, tracks energy usage, and controls HVAC equipment based on occupancy

June 2 -5, 2002

www.energy2002.ee.doe.gov

15



#### NVFEL - ECM 6

#### **Process Water Conservation**

 Use chilled water to cool process loads at the facility

June 2 -5,2002

 $www.\,energy 2002.ee.doe.gov$ 



#### **Power Factor Correction**

- NVFEL is supplied with power by Detroit Edison under the Primary Supply Rate service classification
  - This rate structure includes a reactive demand charge for each kVA of lagging demand
- NORESCO installed capacitators and controls to increase the facility power factor to at least 90%, the penalty threshold

June 2 -5, 2002

www.energy2002.ee.doe.gov

17



#### NVFEL - ECM 10

#### Natural Gas Fuel Cell

- Installed a 200 kW fuel cell powered by natural gas
  - Provides stable power
  - Converts natural gas into electricity to provide a quiet, clean and efficient on-site generating system
  - > Dual cooling loops did not materialize
- Electric generation is working

June 2 -5, 2002

www.energy2002.ee.doe.gov





June 2 -5, 2002

www.energy2002.ee.doe.gov

19



#### NVFEL - ECM 11

## Cold Test Facility – Conversion to Central Plant Cooling

 Improved efficiency of Cold Test Facility chiller system by serving it with chilled water from the central plant

June 2 -5, 2002

 $www.\ energy 2002.ee. doe.gov$ 



## Results of ESPC

(January 1, 2001 - December 31, 2001)

ECM	Electrical Savings (kWh)	Water Savings (Gal)	Fossil Fuel Savings (Mtbu)
ECM –1 Test Cell AHU	2,282,727	6,636,761	50,296,092
ECM-2 Soak Area AHU	409,922	1,118,925	16,532,768
ECM-3 Office and Preparation Area AHU	1,249,443	1,913,020	14,212,372
ECM-4 Replace Boilers and Chillers	757,603	0	(9,719,424)
ECM-5 Install EMS	120,271	0	3,283,019
ECM-6 Process Water Conservation	(5,604)	11,422,149	(406,013)
ECM-8 Power Factor Correction	0	0	0
ECM-10 Natural Gas Fuel Cell	1,187,717	0	(7,966,809)
ECM-11 Cold Test Facility – Conversion to Central Plant Cooling	19,270	0	(71,739)
TOTALS	6,021,350	21,090,854	66,160,265

June 2 - 5, 2002

www.energy2002.ee.doe.gov

21



# Measurement & Verification (M&V)

## M&V Plan : Documenting Energy Savings

- EMS tracks energy performance of new equipment
  - > comprehensive data logging
  - > EMS continuously logs variables and calculates energy usage by system
  - NORESCO accesses stored data and sends to M&V group for processing

June 2 -5, 2002

 $www.\,energy 2002.ee.doe.gov$ 



## Measurement & Verification (M&V)

## Evaluating the M&V Plan


- □ Third party evaluation of M&V report
  - ➤ Architectural Energy Corporation (AEC)
- EMS tracks energy performance and calculates real time energy savings
  - AEC looked at each ECM to determine if EMS calculated energy savings as specified in M&V plan

June 2 -5, 2002

www.energy2002.ee.doe.gov


23







Total \$ Savings (January 1, 2001 – December 31 2001)					
ЕСМ	Electrical Savings (8 kWh)	Water Savings (\$ Gal)	Fossil Fuel Savings (\$ Mtbu)	Total \$ Savings	
ECM-1	\$66,854	\$27,184	\$213,837	\$307,875	
ECM-2	\$12,005	\$4,757	\$70,290	\$87,052	
ECM-3	\$35,857	\$7,836	\$60,425	\$104,117	
ECM-4	\$22,188	\$0	(\$41,323)	(\$19,135)	
ECM-5	\$3,522	\$0	\$13,958	\$17,480	
ECM-6	(\$164)	\$46,785	(\$1,726)	\$44,895	
ECM-8	\$0	\$0	\$0	\$0	
ECM-10	\$34,784	\$0	(\$33,871)	\$913	
ECM-11	\$564	\$0	(\$305)	\$259	
Sub Total	\$175,610	\$86,562	\$281,284	\$543,456	
Sub Total	+ Demand Charge	of \$489, 434 =	TOTAL SAVINGS	\$1,032,890	
Annual Guaranteed Savings - Second Year			\$1,093,856		
Less Annual Maintenance Savings – Second Year			\$205,062		
Amount Above Guarantee			\$144,096		





Electrical & Fossil Fuel Savings			Emissions Offsets (Combined)			
ECM	kWh	Mbtu	CO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	SO <sub>2</sub> (tons)	
1	2,282,727	50,296,092	4,805	7.5	10.4	
2	409,922	16,532,768	1,287	1.7	1.98	
3	1,249,443	14,212,372	1,876.2	3.4	5.5	
4	757,603	-9,719,424	100	1.18	3	
5	120,271	3,283,019	288.8	.4	.55	
6	-5,604	-406,013	-27.7	03	03	
8	0	0	0	0	0	
10	1,187,717	-7,966,809	568.1	2.2	4.9	
11	19,270	-71,739	12.47	.03	.08	
TOTAL	6,021,34	66,160,266	8,910	16.5	26.5	
	<u> </u>	www.en	ergy2002.ee.doe	gov	29	



## Trading Value

	Electrical (kWh)	Natural Gas	CO <sub>2</sub> (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)
		(WHDU)			
Savings	6.021.349	66 160 266	8.910	26.5	16.5

- Refire carbon
- $\hfill NO_x$  : = \$7,425 to \$29,700 (16.5 tons x 0.9 (MDEQ air quality retirement) x \$500 to \$2000)\*
- □ Federal SIP  $NO_x$ : forward trade for 2003: 16.5 tons x \$5,900 = \$97,350
- $\square$  SO<sub>2</sub>: \$13,250 to \$53,000 (26.5 tons x \$500 to \$2000)\*
- \* values based on Michigan ERC

June 2 -5, 2002

www.energy2002.ee.doe.gov



### Intangible Benefits

#### What Else Do We Gain?

- Ability to make major upgrades
- □ Meet Executive Order 13123 goals
  - Executive Order does not exempt laboratories
- Model for other laboratory facilities
- Living agency's mission

June 2 - 5, 2002

www.energy2002.ee.doe.gov

31



### Ada, Oklahoma

- Replicate Ann Arbor in more traditional lab
- Using DOE's Super ESPC
- Shorter lead time
  - ▶ 16 months from project award to completion
  - > Versus 30 months for Ann Arbor
- Drilling 175 geothermal wells (completed) and ground source heat pump
- Improving mechanical systems
- □ Anticipated energy use reduction: 60% June 2 -5,2002 www.energy 2002.ee.doe gov



## Laboratories for the 21<sup>st</sup> Century (Labs21)

- A joint EPA/DOE program to improve the environmental performance of U.S. laboratories
- The goal of the program is to encourage the design, construction, and operation of sustainable, high-performance, facilities that will:
  - Minimize overall environmental impacts
  - Protect occupant safety
  - Optimize whole building efficiency on a life-cycle basis

June 2 - 5, 2002

www.energy2002.ee.doe.gov

21



## Labs21: Program Components

- □ Pilot Partnership Program
- Training
- Best Practices
- Labs21 2002 Annual Conference, October 7-9, 2002, Durham, North Carolina
- Labs21 Web site: www.epa.gov/labs21century

June 2 -5, 2002

www.energy2002.ee.doe.gov